



THE COUNTY OF GALVESTON

RUFUS CROWDER, CPPO CPPB
PURCHASING AGENT

ERIN QUIROGA, MBA, CPPB
ASSISTANT PURCHASING AGENT

COUNTY COURTHOUSE
722 Moody (21st Street)
Fifth (5th) Floor
Galveston, Texas 77550
(409) 770-5371

October 4, 2024

PROJECT NAME: Sidewalks at Bayside Regional Park

SOLICITATION NO: RFP 24-015

RE: Addendum #1

To All Prospective Proposers:

The following information is being provided to aid in preparation of your proposal submittal(s):

Question #1: *Will the cost of any required or requested laboratory testing for soil compaction and concrete strength be paid by Galveston County?*

Response: Yes, it will be paid by the County if needed.

Question #2: *Can surplus excavated soil remain on site or does it need to be disposed of off-site?*

Response: It can be disposed of on site, but location will be coordinated with the Parks Supervisor.

Question #3: *Are we required to plant grass sod along the sides of the new sidewalk where existing grass is disturbed?*

Response: No.

Question #4: *Is Saw Joint Contraction Joints allowed as shown on drawing sheet 09 of 09?*

Response: Yes, the sidewalk can be saw cut. I would recommend trowelling or tooling this joint while not cured for a better look and finish.

Question #5: *Confirm this is a lump sum proposal based on the Concrete Area Quantity listed on drawing sheet 03 of 09.*

Response: This is for the sidewalk in its entirety, plus the installation of the culvert for the concrete bridge and everything required for the installation of the sidewalk and culvert.

Question #6: *Are we required to submit certified payroll reports for this project?*

Response: This is not a grant funded project, so no.

Question #7: *Would you please post the pre-proposal sign in sheet?*

Response: Attached you will find the sign-in sheet from the pre-proposal conference/site visit on September 25, 2024.

Question #8: *DWG sheet 09 of 09 Expansion Joint detail does not list dowel size for 4.5" paving/sidewalk. List ¾" for 6" to 7" paving. Is that what we are to use?*

Response: Yes, ¾" is what should be used.

Question #9: *Dwg sheet 09 of 09 Saw-Cut Contraction Joint detail states to saw cut joint. Can this joint be tooled when pouring? What is the required spacing?*

Response: The typical spacing for sidewalk contraction joints is 4.5-5-6 feet evenly spaced between contracting joints for aesthetics. The spacing for contraction joints is equal to the width of the sidewalk, up to a maximum of 7 feet. Yes, they can be tooled. The spacing required for expansion joints is 8-12 feet evenly spaced for aesthetics.

If you have any further questions regarding this solicitation, please address them to the following representative or contact the Purchasing Department at (409) 770-5371.

Rufus G. Crowder, CPPO CPPB
Galveston County Purchasing Agent
722 Moody, Fifth (5th) Floor
Galveston, Texas 77550
E-mail: rufus.crowder@co.galveston.tx.us

Please excuse us for any inconvenience that this may have caused.












Sincerely,



Rufus G. Crowder, CPPO CPPB
Purchasing Agent
Galveston County

**PRE-PROPOSAL CONFERENCE/SITE VISIT
 SIDEWALKS AT BAYSIDE REGIONAL PARK
 GALVESTON COUNTY, TEXAS**

The Pre-Proposal Conference/Site Visit for RFP 24-015 will be held on Wednesday, September 25, 2024 at 10:30 a.m. at Bayside Regional Park 4833 10th Street, Bacliff, TX 77518

PRINTED NAME	SIGNATURE	COMPANY NAME	PHONE #	E-MAIL ADDRESS
Rufus Crowder		Galv. Co. Purchasing	(409) 770-5372	rufus.crowder@co.galveston.tx.us
Kit Glick		Solo Properties LLC	713-248-6790	Kit@SoloPropertiesLLC.com
Lance Loftin		White Wing Construction	832-507-0005	lloftin@whitewingconst.com
Jahan Shafiq		South Houston Asphalt/Concrete	832-727-2393	J.Shafiq@shac-us.com
Leonardo Villacreses		CONCREMET LLC	346-715-4103	leo.villacreses@conarmet.com
Jimmy Gibson		G County Parks	409-443-4892	Jimmy.Gibson@Co.Galveston.TX.US
Jose J Garcia		5 Stone	(956) 261-0095	Reina@5stoneconstructionllc.com
Abelino Reina		5 Stone	(956) 261-0095	Reina@5stoneconstructionllc.com
Julie Diaz		Galveston County	409-934-8114	julie.diaz@co.galveston.tx.us
Mark Haven		LSA Engineers	713 450 1300	mhaven@LSA.com
Briant Kuchera		LJA Engineering	832-324-6417	bkuchera@LSA.COM