



THE COUNTY OF GALVESTON

RUFUS G. CROWDER, CPPO, CPPB
PURCHASING AGENT

GWEN MCLAREN, CPPB
ASST. PURCHASING AGENT

COUNTY COURTHOUSE
722 Moody (21st Street)
Fifth (5th) Floor
GALVESTON, TEXAS 77550

December 29, 2020

PROJECT NAME: Outdoor Pavilion at Bayside Regional Park
SOLICITATION NO: RFQ #B211021
RE: ADDENDUM #1

To All Prospective Qualifiers:

The following information is being provided to aid in preparation of your qualification submittal(s):

Question #1: *Need the length and width of the building, and the eve height.*

Response: Pavilion size 30' x 60'; footing size – 2' x 2'; eve height – 10 feet

Question #2: *Need spec on materials. I suggest as a basis of design the following:*

- *Hot Dip Galvanized structural member*
- *Pre galvanized secondary members (purlins & girts)*
- *Roof panel MBCI White Solar Kynar coating*
- *Wall panels MBCI R-Panel Kynar coated*
- *Trim material MBCI Kynar coated*

Response: Any brand meeting or exceeding the specifications can be submitted. An example of the desired product can be referenced at this website: <http://romtec.com/standard-pavilions-and-shelters/>

Question #3: *Are we to only design and build the foundation and building structure or are we to provide an ADA compliant path of access from a parking area to the pavilion? If we need to provide a path to the pavilion we will need a clear designation of the ADA parking area and the new pavilion locations?*

Response: Yes, only design and build for the slab and pavilion structure. All ADA pathways will be done in-house.

Question #4: *The existing pavilion example pictures are not very clear. Can color pictures be provided?*

Response: Please see below.



Question #5: *Do you prefer hipped end walls? One of the pictures seems to indicate hipped end walls, and another indicates gable end walls with gables having siding.*

Response: We would prefer gable end walls.

Question #6: *Will gutters and downspouts be required?*

Response: No

Question #7: *Need pavilion width, length, eave height, roof pitch?*

Response: Pavilion size 30' x 60'; footing size – 2' x 2'; eave height – 10 feet; roof pitch 3/12.

If you have any further questions regarding this bid, please address them to:

Rufus G. Crowder, CPPO CPPB
Galveston County Purchasing Agent
722 Moody, Fifth (5th) Floor
Galveston, Texas 77550
E-mail: purchasing.bids@co.galveston.tx.us

or contact the Purchasing Department at (409) 770-5371.

Please excuse us for any inconvenience that this may have caused.

Sincerely,



Rufus G. Crowder, CPPO CPPB
Purchasing Agent
Galveston County



THE COUNTY OF GALVESTON

RUFUS G. CROWDER, CPPO, CPPB
PURCHASING AGENT

GWEN MCLAREN, CPPB
ASST. PURCHASING AGENT

COUNTY COURTHOUSE
722 Moody (21st Street)
Fifth (5th) Floor
GALVESTON, TEXAS 77550

December 29, 2020

PROJECT NAME: Outdoor Pavilion at Bayside Regional Park
SOLICITATION NO: RFQ #B211021
RE: ADDENDUM #2

To All Prospective Qualifiers:

The following information is being provided to aid in preparation of your qualification submittal(s):

Question #1: *Will a site plan, drainage plan, electrical plan, concrete plan and building plan all signed by engineer be needed to pull permit through the Galveston County Permit Department?*

Response: Engineering plans are not required for that area. The County requests a front view, side view, floor plan, and a site and drainage/grading plan. One set no larger than 11x17 is requested.

Question #2: *What elevation does the finished floor of the slab need to be to obtain a permit?*

Response: There is not a finished floor requirement for this structure.

Question #3: *Is an elevation certificate needed?*

Response: No, an elevation certificate is not needed.

Question #4: *Will TABS inspection be needed?*

Response: We do not require a TABS inspection. The County will handle the TDLR permit once the project is complete. Contractors do not have to handle this.

If you have any further questions regarding this bid, please address them to:

Rufus G. Crowder, CPPO CPPB
Galveston County Purchasing Agent
722 Moody, Fifth (5th) Floor
Galveston, Texas 77550
E-mail: purchasing.bids@co.galveston.tx.us

or contact the Purchasing Department at (409) 770-5371.

Please excuse us for any inconvenience that this may have caused.

Sincerely,

A handwritten signature in black ink that reads "Rufus Crowder". There is a small "RD" written above the name.

Rufus G. Crowder, CPPO CPPB
Purchasing Agent
Galveston County